

	Index No.	28
Lane-Scott Electric Cooperative, Inc.	Schedule	PGSR-09
	Replacing Schedule	04-PGS
All Territory (Territory to which schedule is applicable)	Which was issued	March 1, 2009

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein.

Sheet 1 of 3

PARALLEL GENERATION RIDER

DEFINITIONS:

Customer-generator:

The owner or operator of a qualified electric energy generation unit which:

- (a) Is powered by a "Qualifying Facility" for co-generation or small power production as defined in Subpart B of the Public Utility Regulatory Policies Act of 1978 (PURPA), and 18 CFR Part 292;
- (b) Is located on a premises owned, operated, leased, or otherwise controlled by the Customer-generator;
- (c) Is interconnected and operates in parallel phase and synchronization with the Cooperative;
- (d) Is intended primarily to offset part or all of the Customer-generator's own electrical energy requirements;
- (e) Meets all applicable safety, performance, interconnection, and reliability standards established by the National Electrical Code, the National Electrical Safety Code, the Institute of Electrical and Electronics Engineers, Underwriters Laboratories, the Federal Energy Regulatory Commission, and any local governing authorities; and
- (f) Contains a mechanism that automatically disables the unit and interrupts the flow of electricity back onto the supplier's electricity lines in the event that service to the Customer-generator is interrupted.

Each meter connected under this Rider defines a Customer-generator. A generator owned or operated by a Customer-generator cannot be connected in common with any other meter or be deemed to be for the purpose of serving the load connected to any other meter.

AVAILABILITY:


Service is available under this rider at points on the Cooperative's existing electric distribution system, located within its service area, for Customers operating Qualifying Facilities. Service under this rider is not applicable to standby or resale electric service.

APPLICABILITY:

This rider is applicable to Customer-generators with a Cooperative-approved interconnection agreement. This schedule is not applicable where the nameplate capability of the Customer's electrical generating system exceeds 200 kW.

CHARACTER OF SERVICE:

Alternating current, 60 cycles, at the voltage and phase of the Cooperative's established secondary distribution system immediately adjacent to the service location.

Issued	January 4 2010	By	
	Month Day Year		Signature of Officer
Effective	January 4 2010	Title	President
	Month Day Year		

Lane-Scott Electric Cooperative, Inc.		Index No. <u>28</u>
	Schedule	PGSR-09
	Replacing Schedule	04-PGS
All Territory	Which was issued	March 1, 2009
(Territory to which schedule is applicable)		

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein.

Sheet 2 of 3

BILLING AND PAYMENT:

The Cooperative shall render a bill for consumption at approximately 30-day intervals during the Cooperative's normal billing interval. Billing by the Cooperative to the Customer shall be in accordance with the applicable rate schedule. For electrical energy delivered by the Customer to the Cooperative from the Customers Qualifying Facility, the Cooperative shall pay one-hundred percent (100%) of the Cooperatives monthly system average cost of energy per kilowatt hour received. Any such amount shall be paid at least annually or when such amount is \$25 or more.

TERMS AND CONDITIONS:

1. The Cooperative will supply, own and maintain at its expense all necessary meters and associated equipment utilized for billing. In addition, and for purposes of monitoring Customer generation and load, the Cooperative may install at its expense, load research metering. The Customer shall supply, at no expense to the Cooperative, a suitable location for meters and associated equipment used for billing and for load research. Such equipment shall be accessible at all times to utility personnel. The Customer-generator shall reimburse the Cooperative for the cost of any additional distribution facilities necessary to accommodate the Customer-generators facility.
2. The Cooperative shall have the right to require the Customer, at certain times and as electric operating conditions warrant, to limit the production of electrical energy from the generating facility to an amount no greater than the load at the Customer's facility of which the generating facility is a part.
3. The Customer shall furnish, install, operate and maintain in good order and repair without cost to the Cooperative such relays, locks and seals, breakers, automatic synchronizers, disconnecting devices, and other control and protective devices as shall be designated by the Cooperative as being required as suitable for the operation of the generator in parallel with the Cooperative's system.
4. The Customer shall install and maintain a visible, manual disconnect switch. This manual switch must have the capability to be locked out by Cooperative personnel to isolate the Cooperative's facilities in the event of an electrical outage on the Cooperative's transmission and distribution facilities serving the Customer. This isolating device shall also serve as a means of isolation for the Customer's equipment during any Customer maintenance activities, routine outages or emergencies. The Cooperative shall give notice to the Customer before a manual switch is locked or an isolating device used, if possible; and otherwise shall give notice as soon as practicable after locking or isolating the Customer's facilities.
5. The Customer may be required to reimburse the Cooperative for any equipment, facilities, protective equipment or upgrades required solely as a result of the installation by the Customer of generation in parallel with the Cooperative's system.
6. The Customer shall notify the Cooperative prior to the initial energizing and start-up testing of the Customer-owned generator, and the Cooperative shall have the right to have a representative present at said test.
7. If harmonics, voltage fluctuations, or other disruptive problems on the utility's system are directly attributable to the operation of the Customer's system, such problem(s) shall be corrected at the Customer's expense.


Issued	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">January</td> <td style="text-align: center;">4</td> <td style="text-align: center;">2010</td> </tr> <tr> <td style="text-align: center;">Month</td> <td style="text-align: center;">Day</td> <td style="text-align: center;">Year</td> </tr> </table>	January	4	2010	Month	Day	Year	By	
January	4	2010							
Month	Day	Year							
			Signature of Officer						
Effective	<table style="width: 100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">January</td> <td style="text-align: center;">4</td> <td style="text-align: center;">2010</td> </tr> <tr> <td style="text-align: center;">Month</td> <td style="text-align: center;">Day</td> <td style="text-align: center;">Year</td> </tr> </table>	January	4	2010	Month	Day	Year	Title	President
January	4	2010							
Month	Day	Year							

Lane-Scott Electric Cooperative, Inc.		Index No. <u>28</u>
	Schedule	PGSR-09
All Territory	Replacing Schedule	04-PGS
(Territory to which schedule is applicable)	Which was issued	March 1, 2009

The cooperative's bylaws, rules and regulations are supplemental to this schedule and are incorporated herein.

Sheet 3 of 3

8. No Customer's generating system shall damage the Cooperative's system or equipment or present an undue hazard to Cooperative personnel. The Cooperative shall not be liable directly or indirectly for permitting or continuing to allow an attachment of a qualifying facility or for the acts or omissions of a Customer-generator that cause loss or injury, including death, to any third party. The Customer-generator agrees to hold the Cooperative harmless from injury or property damage incurred by any person and arising out of the ownership, operation, maintenance, or use of the parallel generation facility and to indemnify the Cooperative against all liability and expense related thereto.
9. Prior to installing and interconnecting a Qualifying Facility the Customer shall enter into a standard interconnection contract with the Cooperative setting forth the conditions related to technical and safety aspects of parallel generation.
10. Service under this Rider is subject to the Cooperative's Rules and Regulations as adopted by the Board of Trustees and any subsequently approved modifications that may be adopted by said Board during the term of service.
11. The Customer-generator shall, at its own expense, maintain in force general liability insurance without any exclusion for liabilities related to the interconnection. The amount of such insurance shall be sufficient to insure against all reasonably foreseeable direct liabilities given the size and nature of the generating equipment being interconnected, the interconnection itself and the characteristics of the system to which the interconnection is made.
12. Applications by a Customer-generator for interconnection of the qualified generation unit to the distribution system shall be accompanied by the plan for the Customer-generator's electrical generating system, including, but not limited to, a wiring diagram and specifications for the generating unit, and shall be reviewed and responded to by the Cooperative within 30 days after receipt for systems of 10 kilowatts or less and within 90 days after receipt for all other systems. Prior to the interconnection of the qualified generation unit to the supplier's system, the Customer-generator shall furnish the Cooperative a certification from a qualified professional electrician or engineer that the installation meets the requirements of paragraph f, above. If the application for interconnection is approved by the Cooperative and the Customer-generator does not complete the interconnection within one year after receipt of notice of the approval, the approval shall expire and the Customer-generator shall be responsible for filing a new application. Upon the change in ownership of a qualified Renewable Energy Resource, the new Customer-generator shall be responsible for filing a new application under this section.

Issued	January	4	2010	By	
	Month	Day	Year		Signature of Officer
Effective	January	4	2010	Title	President
	Month	Day	Year		